

**MAINTENANCE & ENGINEERING UNIT
ICAR-INDIAN AGRICULTURAL RESEARCH INSTITUTE
NEW DELHI-12.**

No. MEU (EW)/22-23/12


Dated: 03.09.2022

SHORT QUOTATION NOTICE

The quotation are hereby invited on behalf of the Director, IARI from the Contractors Registered with CPWD, MES, Railways, MCD, PWD or other Central/State Govt./Semi Govt. or Specialized agencies The contractor must have valid PAN and GST registration number and having experience of two similar nature of works in last three years for the work mentioned below:

Name of work & location	Estimated cost (₹)	Last date & time of bid submission	Date & time of bid opening
Renovation of provision of conditioning in glass house for Pathological Experiment of Genetics Division at IARI, New Delhi-12.	₹ 5,41,010.00	Upto 14:30 hours 12.09.2022	12.09.2022 at 15:00 hours

Desirous and eligible agencies to download the schedule. The rates on schedule and requisite eligibility documents should be filed in a separate envelopes submitted both together in a bigger envelope. The Director IARI reserves the right to reject or accept any Quotation without assigning any reason. Quotations shall be submitted along with forwarding letter addressed to Admin. Officer (W), ME Unit, IARI, New Delhi-110012.


Admn. Officer (Works)

**Renovation of provision of air conditioning in glass house for Pathological experiment of Genetics
Division at ICAR-IARI, New Delhi-12**

S.No	Items	Qty	Unit	Rate	Amount
1	Supply, installation, testing and commissioning of fully charge (or top-up as per site requirement) 1.5 TR, 230 volt., Three/Five star rated (minimum),BEE/COP (minimum) split air-conditioning units (suitable for commercial/Industrial use at ambient temperature of 52 deg. Celsius) with scroll compressor complete with indoor and outdoor units comprising of blowers, motors, COPPER cooling (tube) coil, COPPER condenser (tube) coil with aluminium fins, condenser fan and copper pipes, 13mm nitrile rubber insulation, heavy duty PVC drain pipe & ISI mark interconnected control cable (2.5sq.mm or suitable size) from indoor to outdoor units, suitable size of heavy duty MS stand for outdoor unit (wall or floor mounted of ISI mark MS 75x75x6mm duly double coat painted after one coat of primer), suitable size heavy duty PVC channel (for covering of copper pipe, cable, & drain pipe) etc upto 4 mtr complete as required and as per standard specification of original manufacturer meet out the above technical requirement. Including breaking of wall/ ceiling and repairing after completion of each work, pressure/leak testing with gas and other accessories etc as required. Make: - Voltas, Hitachi, O general, Daikin	8	Set		
3	Providing & fixing of Extra annealed temper copper piping of following size with all supports and 13 mm nitrile rubber insulation with other accessories i.e breaking of wall/ceiling & repairing after completion of each work, breezing etc as per site requirement to complete the job in all respect.				
a)	Annealed temper copper pipe 5/8", out side dia 0.625", inside dia 0.555 and wall thickness 0.035" with 13 mm nitrile rubber insulation etc	47	Mtr		
b)	Annealed temper copper pipe 1/4", out side dia 0.250", inside dia 0.190 and wall thickness 0.030" with 13 mm nitrile rubber insulation etc	47	Mtr		
4	Proving & fixing interconnected/main 1.1 KV, mutlistrand, FRLS 4 Core x 2.5 Sq.mm wire & other accessories as per site requirement to complete the job in all respect. Make: - Finolex, havells, CMI	120	Mtr		
5	Providing and fixing of 25mm heavy duty, hard PVC pipe line for drain with elbow, bend,13mm insulation, etc.	80	Mtr		
				Total	

Note :- Contractor

Contractor Singnature with seal

Terms & conditions:-

- 1 The work should be executed as per manufacturer specificatins.
- 2 2% Income-tax & surcharge on it ,Work Contract tax/VAT as per govt. norms will be recovered.
- 3 The work is of urgent nature & shall be start execution immediately after the award of the work order without any pre conditions & completed within 20 days, failing which without any genuine reasons, a penalty of 5% of the total work per week shall be imposed or business will be banned in IARI.
- 4 The Director IARI has the right to reject any or all the tender without assigning any reason.